

Hutcherson, Robert

From: Hutcherson, Robert
Sent: Friday, January 08, 2016 11:07 AM
To: Palermo, Anthony
Cc: Dickson, Benjamin
Subject: Positano at Miromar

Tony,

I have reviewed the FPA for the above referenced project as requested and have the following comments.

- A. The proposed stone/concrete wall must be removed from the lake maintenance easement prior to Development Order approval.
- B. A structural equivalency analysis for the pavers vs. asphalt must be submitted with the Development Order application.
- C. The parking layout underneath the building must be provided with the Development Order application.

Please let me know if you have any questions.

Robert Hutcherson, AICP
Development Services Representative
(239) 533-8890
Fax: (239) 485-8344