

TICE FIRE & RESCUE DISTRICT

Ted Ross, Jr
Fire Chief
(239) 694-2380
tross@ticefire.com

9351 Workmen Way
Ft. Myers, Fl. 33905
Fax (239) 694-7399
www.ticefire.com

June 28, 2022

PENINSULA ENGINEERING
Daniel C. Hartley, P.E.
2600 Golden Gate Parkway
Naples, Florida 34105

RE: Cypress Woods RVPD - Request for Deviation

Mr. Hartley,

Tice Fire & Rescue District has reviewed the request for deviation from Lee County LDC Section 10-415(b)(1)(c), which states that *"A minimum setback of 20 feet from buildings is required. For indigenous plant communities subject to fire, such as pine flatwoods, palmetto prairie and xeric scrub, a 30-foot setback is required for fire protection."*, to allow a 20' setback between the accessory structures upon Lots 121-137 and the indigenous restoration area north of those lots.

Tice Fire & Rescue District does not object and supports the deviation as requested.

If you have any questions, please contact me at (239) 694-2380.

Respectfully,



Ted A Ross Jr.
Fire Chief /
Fire Marshal